

September 29, 2017

Dear Parents/Guardians:

Our school system is committed to protecting students and staff. To protect our school community and to be in compliance with the New Jersey Department of Education (NJDOE) regulations, the Irvington Township School District tested all drinking water outlets for lead on September 13, 2017. The District received a report getting the results of the testing on September 18, 2017.

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the Irvington Township School District. Through this effort, we identified and tested all drinking water outlets.

In accordance with the NJDOE regulations, Irvington Public Schools has taken steps to implement immediate remedial measures for any water outlet that tested above the action level. This includes turning off and/or removing outlets.

Detailed Results of our Testing

The table below identifies the drinking water outlets that tested above the 15 ug/1 for lead, the actual lead level, and what remedial action the Irvington Public Schools has taken to reduce the levels of lead at these locations. Following remediation, all identified sites will be tested again.

School	Sample Number	Location	Remediation
University Elementary School	UES-WF-18 19.2	3 rd Floor/Room 309 (room was not occupied in the 2016-2017 school year)	Filter Installed 9/19/17
University Elementary School	UES-KF-02 16.4	Kitchen	Filter Installed 9/23/17
Madison	MAD-WF-08	Ground	Filter Installed 9/19/17

	92.2	Floor/Hallway (tested negative in July 2016 - 0.82)	
Madison	MAD-WF-06 786.0	1 ST Floor/Hallway adjacent to Room 16 (tested negative in July 2016 - 5.59)	Removed 9/19/17
Madison	MAD-WF-05 18.7	1 ST Floor/Hallway adjacent to Room 17 (tested negative in July 2016- 0.28)	Removed 9/19/17
Madison	MAD-WF-02 55.7	2 ND Floor/Hallway adjacent to Room 25 (tested negative in July 2016- 1.10)	Removed 9/19/17
Grove Street School	GSS-WF-02 1,240.0	1 ST Floor/Room 108	Filter Installed 9/19/17
Grove Street School	GSS-WF-07 1,080.0	1 ST Floor/ Computer Lab 247 (room not occupied in the 2015-2016 or 2016- 2017 school year)	Removed 9/20/17
Grove Street School	GSS-WF-01 30.6	Kitchen	Filter Installed 9/18/17
Mount Vernon School	MV-WF-019 17.6	2 nd Floor/Room 228	Filter Installed 9/20/17
Mount Vernon School	MV-WF-033	1 ST Floor/Room 136	Filter Installed 9/20/17

	58.7		
Mount Vernon School	MV-WF-037 25.4	1 ST Floor/Room 128	Filter Installed 9/20/17
Mount Vernon School	MV-KF-01 41.2	Kitchen	Small Hand Wash Sink only (no filter needed)
Mount Vernon	MV-KF-02 114.0	Kitchen	Filter Installed 9/20/17
Mount Vernon School	MV-KF-03 27.9	Kitchen	Hand wash sink only (no filter needed)
Florence Avenue School	FAS-WF-02 47.0	1 st Floor/ Hallway/outside Guidance Office	Eyewash station Filter Installed 9/21/17
Florence Avenue School	FAS-WF-05 1,400.0	1 st Floor/ Hallway outside Room 112 (tested negative in July 2016 - 3.05)	Filter Installed 9/21/17
Florence Avenue School	FAS-WF-011 15.7	Basement/Hallway outside main office	Removed 9/21/17
Augusta Pre-School	APS-WF-016 21.6	2 nd floor Room 202 (tested negative in July 2016- 3.73)	Changed filter that was installed in Spring 2017 9/19/17
Augusta Pre-School	APS-WF-024 34.2	2 nd Floor Room 210 (tested negative in July 2016- 2.22)	Changed filter that was installed Spring 2017 9/19/17
Irvington High School	IHS-WF-05 24.7	1 st Floor / Hallway adjacent to classroom 106 (tested negative in	Filter Installed 9/20/17

		July 2016- 6.5)	
Irvington High School	IHS-KF-01 18.9	Kitchen	Filter Installed 9/20/17
Irvington High School	IHS -KF-04 19.8	Kitchen	Filter Installed 9/20/17
University Middle School	UMS-WF-03 1,560.0	3 rd floor / Hallway adjacent to Stairwell 3	Filter Installed 9/21/17
Union Avenue Middle School	No Exceedances		
Thurgood Marshall School	No Exceedances		
Berkeley Terrace School	No Exceedances		
Chancellor Avenue School	No Exceedances		

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2 % lead, and restricted the lead content of faucets, pipes and other plumbing materials.

For More Information

A copy of the available test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 am and 4:00 pm and are also available on our website www.Irvington.k12.nj.us. For more information about water quality in our schools, contact Roger Monel, Associate School Business Administrator 973-399-6800 ext. 2121.

Sincerely,

Dr. Neely Hackett,
Superintendent of Schools

IRVINGTON BOARD OF EDUCATION
Union Avenue Middle School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1st Floor / Hallway adj. to Auditorium	31553.09.01 Union Avenue Middle School	UAMS-WF-01	7090504-01	Potable Water	08/29/2017 00:00:00	09/12/2017 12:15:55	EPA 200.5	Lead	7439-92-1	7.04	ug/L
1st Floor / Hallway adj. to Auditorium	31553.09.01 Union Avenue Middle School	UAMS-WF-02	7090504-02	Potable Water	08/29/2017 00:00:00	09/12/2017 12:17:54	EPA 200.5	Lead	7439-92-1	1.06	ug/L
1st Floor / Hallway adj. to Toilet 1066	31553.09.01 Union Avenue Middle School	UAMS-WF-04	7090504-04	Potable Water	08/29/2017 00:00:00	09/12/2017 12:19:54	EPA 200.5	Lead	7439-92-1	9.13	ug/L
1st Floor / Hallway adj. to Classroom 1035	31553.09.01 Union Avenue Middle School	UAMS-WF-06	7090504-06	Potable Water	08/29/2017 00:00:00	09/12/2017 12:21:53	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway adj. to Classroom 1035	31553.09.01 Union Avenue Middle School	UAMS-WF-08	7090504-08	Potable Water	08/29/2017 00:00:00	09/12/2017 12:23:52	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway adj. to Classroom 1035	31553.09.01 Union Avenue Middle School	UAMS-WF-09	7090504-09	Potable Water	08/29/2017 00:00:00	09/12/2017 12:25:50	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Library	31553.09.01 Union Avenue Middle School	UAMS-WF-010	7090504-10	Potable Water	08/29/2017 00:00:00	09/12/2017 12:27:49	EPA 200.5	Lead	7439-92-1	1.15	ug/L
2nd Floor / Hallway adj. to Library	31553.09.01 Union Avenue Middle School	UAMS-WF-011	7090504-11	Potable Water	08/29/2017 00:00:00	09/12/2017 12:35:48	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Library	31553.09.01 Union Avenue Middle School	UAMS-WF-013	7090504-13	Potable Water	08/29/2017 00:00:00	09/12/2017 12:37:46	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Classroom 215	31553.09.01 Union Avenue Middle School	UAMS-WF-014	7090504-14	Potable Water	08/29/2017 00:00:00	09/12/2017 12:39:45	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Classroom 215	31553.09.01 Union Avenue Middle School	UAMS-WF-015	7090504-15	Potable Water	08/29/2017 00:00:00	09/12/2017 12:51:39	EPA 200.5	Lead	7439-92-1	0.944	ug/L
2nd Floor / Hallway adj. to Classroom 207	31553.09.01 Union Avenue Middle School	UAMS-WF-016	7090504-16	Potable Water	08/29/2017 00:00:00	09/12/2017 12:53:38	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Classroom 307	31553.09.01 Union Avenue Middle School	UAMS-WF-017	7090504-17	Potable Water	08/29/2017 00:00:00	09/12/2017 13:01:34	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Classroom 317	31553.09.01 Union Avenue Middle School	UAMS-WF-019	7090504-19	Potable Water	08/29/2017 00:00:00	09/12/2017 13:03:34	EPA 200.5	Lead	7439-92-1	3.99	ug/L
3rd Floor / Hallway adj. to Science Lab 329	31553.09.01 Union Avenue Middle School	UAMS-WF-20	7090504-20	Potable Water	08/29/2017 00:00:00	09/12/2017 13:05:33	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Science Lab 329	31553.09.01 Union Avenue Middle School	UAMS-WF-21	7090504-21	Potable Water	08/29/2017 00:00:00	09/12/2017 13:07:33	EPA 200.5	Lead	7439-92-1	1.95	ug/L
3rd Floor / Hallway adj. to Science Lab 329	31553.09.01 Union Avenue Middle School	UAMS-WF-22	7090504-22	Potable Water	08/29/2017 00:00:00	09/12/2017 13:09:32	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Science Lab 329	31553.09.01 Union Avenue Middle School	UAMS-WF-23	7090504-23	Potable Water	08/29/2017 00:00:00	09/12/2017 13:11:31	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Gym	31553.09.01 Union Avenue Middle School	UAMS-WF-24	7090504-24	Potable Water	08/29/2017 00:00:00	09/12/2017 13:13:30	EPA 200.5	Lead	7439-92-1	8.62	ug/L
1st Floor / Gym	31553.09.01 Union Avenue Middle School	UAMS-WF-25	7090504-25	Potable Water	08/29/2017 00:00:00	09/12/2017 13:15:29	EPA 200.5	Lead	7439-92-1	1.77	ug/L
Kitchen	31553.09.01 Union Avenue Middle School	UAMS-KF-01	7090504-26	Potable Water	08/29/2017 00:00:00	09/12/2017 13:33:21	EPA 200.5	Lead	7439-92-1	ND	ug/L

IRVINGTON BOARD OF EDUCATION
 Union Avenue Middle School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
Kitchen	31553.09.01 Union Avenue Middle School	UAMS-KF-02 Kitchen	7090504-27	Potable Water	08/29/2017 00:00:00	09/12/2017 13:35:20	EPA 200.5	Lead	7439-92-1	2.23	ug/L
Kitchen	31553.09.01 Union Avenue Middle School	UAMS-KF-03 Kitchen	7090504-28	Potable Water	08/29/2017 00:00:00	09/12/2017 13:37:20	EPA 200.5	Lead	7439-92-1	11.8	ug/L
Kitchen	31553.09.01 Union Avenue Middle School	UAMS-KF-04 Kitchen	7090504-29	Potable Water	08/29/2017 00:00:00	09/12/2017 13:39:19	EPA 200.5	Lead	7439-92-1	8.96	ug/L

IRVINGTON BOARD OF EDUCATION
University Middle School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
3rd Floor / Hallway adj. to Stair 2	31553.09.01 University Middle School	UMS-WF-01	7090505-01	Potable Water	08/29/2017 00:00:00	09/12/2017 13:41:17	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Stair 3	31553.09.01 University Middle School	UMS-WF-03	7090505-03	Potable Water	08/29/2017 00:00:00	09/12/2017 13:43:16	EPA 200.5	Lead	7439-92-1	1560	ug/L
3rd Floor / Gym	31553.09.01 University Middle School	UMS-WF-04	7090505-04	Potable Water	08/29/2017 00:00:00	09/12/2017 13:45:16	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Stair 4	31553.09.01 University Middle School	UMS-WF-05	7090505-05	Potable Water	08/29/2017 00:00:00	09/12/2017 13:53:13	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Room 203	31553.09.01 University Middle School	UMS-WF-06	7090505-06	Potable Water	08/29/2017 00:00:00	09/12/2017 13:55:11	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Guidance Office	31553.09.01 University Middle School	UMS-WF-07	7090505-07	Potable Water	08/29/2017 00:00:00	09/12/2017 13:57:10	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Stair 4	31553.09.01 University Middle School	UMS-WF-09	7090505-09	Potable Water	08/29/2017 00:00:00	09/12/2017 14:09:05	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway adj. to Stair 2	31553.09.01 University Middle School	UMS-WF-10	7090505-10	Potable Water	08/29/2017 00:00:00	09/12/2017 14:11:04	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway adj. to Teacher's Lounge	31553.09.01 University Middle School	UMS-WF-11	7090505-11	Potable Water	08/29/2017 00:00:00	09/12/2017 14:19:03	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Lobby	31553.09.01 University Middle School	UMS-WF-12	7090505-12	Potable Water	08/29/2017 00:00:00	09/12/2017 14:21:02	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway adj. to Music Classroom	31553.09.01 University Middle School	UMS-WF-13	7090505-13	Potable Water	08/29/2017 00:00:00	09/12/2017 14:22:59	EPA 200.5	Lead	7439-92-1	ND	ug/L
Kitchen	31553.09.01 University Middle School	UMS-KF-01 Kitchen	7090505-16	Potable Water	08/29/2017 00:00:00	09/12/2017 14:24:58	EPA 200.5	Lead	7439-92-1	1.03	ug/L
Kitchen	31553.09.01 University Middle School	UMS-KF-02 Kitchen	7090505-17	Potable Water	08/29/2017 00:00:00	09/12/2017 14:26:57	EPA 200.5	Lead	7439-92-1	ND	ug/L
Kitchen	31553.09.01 University Middle School	UMS-KF-03 Kitchen	7090505-18	Potable Water	08/29/2017 00:00:00	09/12/2017 14:28:56	EPA 200.5	Lead	7439-92-1	ND	ug/L

IRVINGTON BOARD OF EDUCATION
Irvington High School

PROJECT LOCATION	PROJECT NO	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
Basement / Hallway adj. to Special Education Room 026	31553.09.01 Irvington High School	IHS-WF-01	7090506-01	Potable Water	08/29/2017 00:00:00	09/12/2017 14:30:54	EPA 200.5	Lead	7439-92-1	1.36	ug/L
Basement / Hallway adj. to Classroom 012	31553.09.01 Irvington High School	IHS-WF-02	7090506-02	Potable Water	08/29/2017 00:00:00	09/12/2017 14:32:53	EPA 200.5	Lead	7439-92-1	3.63	ug/L
1st Floor / Hallway adj. to Auditorium	31553.09.01 Irvington High School	IHS-WF-03	7090506-03	Potable Water	08/29/2017 00:00:00	09/12/2017 15:11:50	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway adj. to Classroom 106	31553.09.01 Irvington High School	IHS-WF-05	7090506-05	Potable Water	08/29/2017 00:00:00	09/12/2017 15:13:49	EPA 200.5	Lead	7439-92-1	24.7	ug/L
1st Floor / Hallway adj. 10 ROTC Room	31553.09.01 Irvington High School	IHS-WF-06	7090506-06	Potable Water	08/29/2017 00:00:00	09/12/2017 15:15:48	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway adj. to Boys Locker Room	31553.09.01 Irvington High School	IHS-WF-07	7090506-07	Potable Water	08/29/2017 00:00:00	09/12/2017 15:17:46	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Graphics Arts Room	31553.09.01 Irvington High School	IHS-WF-10	7090506-10	Potable Water	08/29/2017 00:00:00	09/12/2017 15:19:45	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Classroom 320	31553.09.01 Irvington High School	IHS-WF-12	7090506-12	Potable Water	08/29/2017 00:00:00	09/12/2017 15:21:43	EPA 200.5	Lead	7439-92-1	2.15	ug/L
3rd Floor / Hallway adj. to Classroom 301	31553.09.01 Irvington High School	IHS-WF-13	7090506-13	Potable Water	08/29/2017 00:00:00	09/12/2017 15:23:42	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway adj. to Cafeteria	31553.09.01 Irvington High School	IHS-WF-14	7090506-14	Potable Water	08/29/2017 00:00:00	09/12/2017 15:31:38	EPA 200.5	Lead	7439-92-1	ND	ug/L
West Wing 500 / next to Room 505	31553.09.01 Irvington High School	IHS-WF-17	7090506-17	Potable Water	08/29/2017 00:00:00	09/12/2017 15:33:37	EPA 200.5	Lead	7439-92-1	4.62	ug/L
West Wing 500 / next to Room 602	31553.09.01 Irvington High School	IHS-WF-19	7090506-19	Potable Water	08/29/2017 00:00:00	09/12/2017 15:35:37	EPA 200.5	Lead	7439-92-1	2.68	ug/L
West Wing 600 / next to Room 606	31553.09.01 Irvington High School	IHS-WF-20	7090506-20	Potable Water	08/29/2017 00:00:00	09/12/2017 15:47:28	EPA 200.5	Lead	7439-92-1	ND	ug/L
Kitchen	31553.09.01 Irvington High School	IHS-KF-01 Kitchen	7090506-21	Potable Water	08/29/2017 00:00:00	09/12/2017 15:49:27	EPA 200.5	Lead	7439-92-1	18.9	ug/L
Kitchen	31553.09.01 Irvington High School	IHS-KF-02 Kitchen	7090506-22	Potable Water	08/29/2017 00:00:00	09/12/2017 15:57:24	EPA 200.5	Lead	7439-92-1	2.12	ug/L
Kitchen	31553.09.01 Irvington High School	IHS-KF-03 Kitchen	7090506-23	Potable Water	08/29/2017 00:00:00	09/12/2017 15:59:23	EPA 200.5	Lead	7439-92-1	4.14	ug/L
Kitchen	31553.09.01 Irvington High School	IHS-KF-04 Kitchen	7090506-24	Potable Water	08/29/2017 00:00:00	09/12/2017 16:01:22	EPA 200.5	Lead	7439-92-1	19.8	ug/L
Kitchen	31553.09.01 Irvington High School	IHS-KF-05 Kitchen	7090506-25	Potable Water	08/29/2017 00:00:00	09/12/2017 16:03:22	EPA 200.5	Lead	7439-92-1	2.33	ug/L

IRVINGTON BOARD OF EDUCATION
Augusta Pre-School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1st Floor / Room 101	31553.09.01 Augusta Pre-School	APS-WF-02	7090507-02	Potable Water	08/30/2017 00:00:00	09/12/2017 16:05:21	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 102	31553.09.01 Augusta Pre-School	APS-WF-03	7090507-03	Potable Water	08/30/2017 00:00:00	09/12/2017 16:07:20	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 103	31553.09.01 Augusta Pre-School	APS-WF-04	7090507-04	Potable Water	08/30/2017 00:00:00	09/12/2017 16:09:18	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 105	31553.09.01 Augusta Pre-School	APS-WF-06	7090507-06	Potable Water	08/30/2017 00:00:00	09/12/2017 16:11:16	EPA 200.5	Lead	7439-92-1	3.49	ug/L
1st Floor / Room 106	31553.09.01 Augusta Pre-School	APS-WF-07	7090507-07	Potable Water	08/30/2017 00:00:00	09/14/2017 11:47:10	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 107	31553.09.01 Augusta Pre-School	APS-WF-08	7090507-08	Potable Water	08/30/2017 00:00:00	09/14/2017 11:49:09	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 108	31553.09.01 Augusta Pre-School	APS-WF-09	7090507-09	Potable Water	08/30/2017 00:00:00	09/14/2017 11:51:08	EPA 200.5	Lead	7439-92-1	1.75	ug/L
1st Floor / Room 109	31553.09.01 Augusta Pre-School	APS-WF-10	7090507-10	Potable Water	08/30/2017 00:00:00	09/14/2017 11:53:07	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 110	31553.09.01 Augusta Pre-School	APS-WF-11	7090507-11	Potable Water	08/30/2017 00:00:00	09/14/2017 11:55:06	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 111	31553.09.01 Augusta Pre-School	APS-WF-12	7090507-12	Potable Water	08/30/2017 00:00:00	09/14/2017 11:57:06	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 112	31553.09.01 Augusta Pre-School	APS-WF-13	7090507-13	Potable Water	08/30/2017 00:00:00	09/14/2017 11:59:06	EPA 200.5	Lead	7439-92-1	0.855	ug/L
2nd Floor / Hallway outside Room 201	31553.09.01 Augusta Pre-School	APS-WF-14	7090507-14	Potable Water	08/30/2017 00:00:00	09/14/2017 12:07:03	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Room 202	31553.09.01 Augusta Pre-School	APS-WF-16	7090507-16	Potable Water	08/30/2017 00:00:00	09/14/2017 12:09:02	EPA 200.5	Lead	7439-92-1	21.6	ug/L
2nd Floor / Room 204	31553.09.01 Augusta Pre-School	APS-WF-18	7090507-18	Potable Water	08/30/2017 00:00:00	09/14/2017 12:11:02	EPA 200.5	Lead	7439-92-1	1.06	ug/L
2nd Floor / Room 205	31553.09.01 Augusta Pre-School	APS-WF-19	7090507-19	Potable Water	08/30/2017 00:00:00	09/14/2017 12:22:55	EPA 200.5	Lead	7439-92-1	4.69	ug/L
2nd Floor / Room 206	31553.09.01 Augusta Pre-School	APS-WF-020	7090507-20	Potable Water	08/30/2017 00:00:00	09/14/2017 12:24:55	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Room 207	31553.09.01 Augusta Pre-School	APS-WF-021	7090507-21	Potable Water	08/30/2017 00:00:00	09/14/2017 12:32:51	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Room 208	31553.09.01 Augusta Pre-School	APS-WF-022	7090507-22	Potable Water	08/30/2017 00:00:00	09/14/2017 12:34:50	EPA 200.5	Lead	7439-92-1	1.18	ug/L
2nd Floor / Room 209	31553.09.01 Augusta Pre-School	APS-WF-023	7090507-23	Potable Water	08/30/2017 00:00:00	09/14/2017 12:36:49	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Room 210	31553.09.01 Augusta Pre-School	APS-WF-024	7090507-24	Potable Water	08/30/2017 00:00:00	09/14/2017 12:38:49	EPA 200.5	Lead	7439-92-1	34.2	ug/L
2nd Floor / Room 211	31553.09.01 Augusta Pre-School	APS-WF-025	7090507-25	Potable Water	08/30/2017 00:00:00	09/14/2017 12:40:48	EPA 200.5	Lead	7439-92-1	1.06	ug/L

IRVINGTON BOARD OF EDUCATION
 Augusta Pre-School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
2nd Floor / Room 212	31553.09.01 Augusta Pre-School	APS-WF-026	7090507-26	Potable Water	08/30/2017 00:00:00	09/14/2017 12:42:47	EPA 200.5	Lead	7439-92-1	1.29	ug/L
Kitchen	31553.09.01 Augusta Pre-School	APS-KF-01 Kitchen	7090507-27	Potable Water	08/30/2017 00:00:00	09/14/2017 12:44:46	EPA 200.5	Lead	7439-92-1	2.40	ug/L
Kitchen	31553.09.01 Augusta Pre-School	APS-KF-02 Kitchen	7090507-28	Potable Water	08/30/2017 00:00:00	09/14/2017 12:46:46	EPA 200.5	Lead	7439-92-1	1.70	ug/L
Kitchen	31553.09.01 Augusta Pre-School	APS-KF-03 Kitchen	7090507-29	Potable Water	08/30/2017 00:00:00	09/14/2017 13:12:47	EPA 200.5	Lead	7439-92-1	ND	ug/L

IRVINGTON BOARD OF EDUCATION
Grove Street School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1st Floor / Hallway outside Kindergarten Room 114	31553.09.01 Grove Street School	GSS-WF-01	7090511-01	Potable Water	08/30/2017 00:00:00	09/14/2017 13:14:46	EPA 200.5	Lead	7439-92-1	9.80	ug/L
1st Floor / Room 106	31553.09.01 Grove Street School	GSS-WF-02	7090511-02	Potable Water	08/30/2017 00:00:00	09/14/2017 15:43:00	EPA 200.5	Lead	7439-92-1	1240	ug/L
1st Floor / Room 105	31553.09.01 Grove Street School	GSS-WF-03	7090511-03	Potable Water	08/30/2017 00:00:00	09/14/2017 13:18:45	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway outside Music Room 103	31553.09.01 Grove Street School	GSS-WF-04	7090511-04	Potable Water	08/30/2017 00:00:00	09/14/2017 13:20:44	EPA 200.5	Lead	7439-92-1	1.45	ug/L
1st Floor / Hallway outside Men's Toilet 246	31553.09.01 Grove Street School	GSS-WF-05	7090511-05	Potable Water	08/30/2017 00:00:00	09/14/2017 13:22:43	EPA 200.5	Lead	7439-92-1	3.58	ug/L
1st Floor / Hallway outside Office 248	31553.09.01 Grove Street School	GSS-WF-06	7090511-06	Potable Water	08/30/2017 00:00:00	09/14/2017 13:24:42	EPA 200.5	Lead	7439-92-1	3.65	ug/L
1st Floor / Computer Lab 247	31553.09.01 Grove Street School	GSS-WF-07	7090511-07	Potable Water	08/30/2017 00:00:00	09/14/2017 15:44:59	EPA 200.5	Lead	7439-92-1	1080	ug/L
2nd Floor / Hallway outside Room 206	31553.09.01 Grove Street School	GSS-WF-011	7090511-11	Potable Water	08/30/2017 00:00:00	09/14/2017 13:34:36	EPA 200.5	Lead	7439-92-1	1.71	ug/L
3rd Floor / Hallway outside Room 307	31553.09.01 Grove Street School	GSS-WF-012	7090511-12	Potable Water	08/30/2017 00:00:00	09/14/2017 13:36:35	EPA 200.5	Lead	7439-92-1	4.83	ug/L
3rd Floor / Hallway outside Room 314	31553.09.01 Grove Street School	GSS-WF-013	7090511-13	Potable Water	08/30/2017 00:00:00	09/14/2017 13:48:31	EPA 200.5	Lead	7439-92-1	3.17	ug/L
Kitchen	31553.09.01 Grove Street School	GSS-KF-01 Kitchen	7090511-14	Potable Water	08/30/2017 00:00:00	09/14/2017 13:50:31	EPA 200.5	Lead	7439-92-1	30.6	ug/L

IRVINGTON BOARD OF EDUCATION
Berkeley Terrace School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1st Floor / Vestibule outside Faculty Kitchen	31553.09.01 Berkeley Terrace School	BTS-WF-01	7090512-01	Potable Water	08/30/2017 00:00:00	09/14/2017 13:58:26	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway at Stair #2	31553.09.01 Berkeley Terrace School	BTS-WF-02	7090512-02	Potable Water	08/30/2017 00:00:00	09/14/2017 14:00:25	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway at Stair #2	31553.09.01 Berkeley Terrace School	BTS-WF-06	7090512-06	Potable Water	08/30/2017 00:00:00	09/14/2017 14:02:23	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway at Stair #1	31553.09.01 Berkeley Terrace School	BTS-WF-07	7090512-07	Potable Water	08/30/2017 00:00:00	09/14/2017 14:04:22	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway at Stair #2	31553.09.01 Berkeley Terrace School	BTS-WF-08	7090512-08	Potable Water	08/30/2017 00:00:00	09/14/2017 14:06:21	EPA 200.5	Lead	7439-92-1	ND	ug/L
Kitchen	31553.09.01 Berkeley Terrace School	BTS-KF-01 Kitchen	7090512-09	Potable Water	08/30/2017 00:00:00	09/14/2017 14:08:20	EPA 200.5	Lead	7439-92-1	1.41	ug/L

IRVINGTON BOARD OF EDUCATION
Chancellor Avenue School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPDATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
2nd Floor / Hallway outside Faculty Break Room 202A	31553.09.01 Chancellor Avenue School	CAS-WF-01	7090513-01	Potable Water	08/30/2017 00:00:00	09/14/2017 14:10:18	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway outside Room 206	31553.09.01 Chancellor Avenue School	CAS-WF-02	7090513-02	Potable Water	08/30/2017 00:00:00	09/14/2017 14:12:17	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway outside Room 207	31553.09.01 Chancellor Avenue School	CAS-WF-03	7090513-03	Potable Water	08/30/2017 00:00:00	09/14/2017 14:31:41	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway outside Room 302	31553.09.01 Chancellor Avenue School	CAS-WF-04	7090513-04	Potable Water	08/30/2017 00:00:00	09/14/2017 14:33:40	EPA 200.5	Lead	7439-92-1	ND	ug/L
3rd Floor / Hallway outside Room 307	31553.09.01 Chancellor Avenue School	CAS-WF-05	7090513-05	Potable Water	08/30/2017 00:00:00	09/14/2017 14:35:39	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway outside Kindergarten Room 108	31553.09.01 Chancellor Avenue School	CAS-WF-06	7090513-06	Potable Water	08/30/2017 00:00:00	09/14/2017 14:37:37	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway outside Kindergarten Room 108	31553.09.01 Chancellor Avenue School	CAS-WF-07	7090513-07	Potable Water	08/30/2017 00:00:00	09/14/2017 14:39:36	EPA 200.5	Lead	7439-92-1	ND	ug/L
Kitchen	31553.09.01 Chancellor Avenue School	CAS-KF-01 Kitchen	7090513-08	Potable Water	08/30/2017 00:00:00	09/14/2017 14:41:35	EPA 200.5	Lead	7439-92-1	ND	ug/L

IRVINGTON BOARD OF EDUCATION
Florence Avenue School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPLE DATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1st Floor / Hallway outside Room 105	31553.09.01 Florence Avenue School	FAS-WF-01	7090605-01	Potable Water	08/30/2017 00:00:00	09/14/2017 14:51:31	EPA 200.5	Lead	7439-92-1	2.88	ug/L
1st Floor / Hallway outside Guidance Office	31553.09.01 Florence Avenue School	FAS-WF-02	7090605-02	Potable Water	08/30/2017 00:00:00	09/14/2017 14:53:30	EPA 200.5	Lead	7439-92-1	0.993	ug/L
1st Floor / Hallway outside Room 108	31553.09.01 Florence Avenue School	FAS-WF-03	7090605-03	Potable Water	08/30/2017 00:00:00	09/14/2017 14:55:30	EPA 200.5	Lead	7439-92-1	47.0	ug/L
1st Floor / Hallway outside Room 112	31553.09.01 Florence Avenue School	FAS-WF-05	7090605-05	Potable Water	08/30/2017 00:00:00	09/14/2017 15:46:58	EPA 200.5	Lead	7439-92-1	1400	ug/L
Basement / Hallway	31553.09.01 Florence Avenue School	FAS-WF-09	7090605-09	Potable Water	08/30/2017 00:00:00	09/14/2017 15:09:19	EPA 200.5	Lead	7439-92-1	4.63	ug/L
Basement / Hallway	31553.09.01 Florence Avenue School	FAS-WF-010	7090605-10	Potable Water	08/30/2017 00:00:00	09/14/2017 15:17:16	EPA 200.5	Lead	7439-92-1	6.51	ug/L
Basement / Hallway outside Office	31553.09.01 Florence Avenue School	FAS-WF-011	7090605-11	Potable Water	08/30/2017 00:00:00	09/14/2017 15:19:14	EPA 200.5	Lead	7439-92-1	15.7	ug/L
Basement / Hallway outside Office	31553.09.01 Florence Avenue School	FAS-WF-012	7090605-12	Potable Water	08/30/2017 00:00:00	09/14/2017 15:21:14	EPA 200.5	Lead	7439-92-1	12.3	ug/L
Kitchen	31553.09.01 Florence Avenue School	FAS-KF-01	7090605-13	Potable Water	08/30/2017 00:00:00	09/14/2017 15:23:13	EPA 200.5	Lead	7439-92-1	2.31	ug/L

IRVINGTON BOARD OF EDUCATION
Mt. Vernon School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPLE DATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1st Floor / Room 326	31553.09.01 Mt. Vernon School	MV-WF-01	7090606-01	Potable Water	08/28/2017 00:00:00	09/14/2017 15:25:12	EPA 200.5	Lead	7439-92-1	1.26	ug/L
1st Floor / Room 331	31553.09.01 Mt. Vernon School	MV-WF-02	7090606-02	Potable Water	08/28/2017 00:00:00	09/14/2017 15:27:11	EPA 200.5	Lead	7439-92-1	3.65	ug/L
1st Floor / Room 333	31553.09.01 Mt. Vernon School	MV-WF-03	7090606-03	Potable Water	08/28/2017 00:00:00	09/14/2017 15:29:09	EPA 200.5	Lead	7439-92-1	2.38	ug/L
1st Floor / Room 328	31553.09.01 Mt. Vernon School	MV-WF-04	7090606-04	Potable Water	08/28/2017 00:00:00	09/14/2017 15:31:07	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 341	31553.09.01 Mt. Vernon School	MV-WF-07	7090606-07	Potable Water	08/28/2017 00:00:00	09/14/2017 15:58:27	EPA 200.5	Lead	7439-92-1	2.04	ug/L
1st Floor / Room 343	31553.09.01 Mt. Vernon School	MV-WF-08	7090606-08	Potable Water	08/28/2017 00:00:00	09/14/2017 16:00:25	EPA 200.5	Lead	7439-92-1	3.03	ug/L
1st Floor / Room 342	31553.09.01 Mt. Vernon School	MV-WF-09	7090606-09	Potable Water	08/28/2017 00:00:00	09/14/2017 16:08:20	EPA 200.5	Lead	7439-92-1	3.18	ug/L
1st Floor / Room 340	31553.09.01 Mt. Vernon School	MV-WF-010	7090606-10	Potable Water	08/28/2017 00:00:00	09/14/2017 16:10:19	EPA 200.5	Lead	7439-92-1	1.99	ug/L
1st Floor / Room 338	31553.09.01 Mt. Vernon School	MV-WF-011	7090606-11	Potable Water	08/28/2017 00:00:00	09/14/2017 16:12:17	EPA 200.5	Lead	7439-92-1	3.40	ug/L
2nd Floor / Room 242	31553.09.01 Mt. Vernon School	MV-WF-012	7090606-12	Potable Water	08/28/2017 00:00:00	09/14/2017 16:14:15	EPA 200.5	Lead	7439-92-1	3.41	ug/L
2nd Floor / Room 243	31553.09.01 Mt. Vernon School	MV-WF-013	7090606-13	Potable Water	08/28/2017 00:00:00	09/14/2017 16:16:14	EPA 200.5	Lead	7439-92-1	2.02	ug/L
2nd Floor / Room 240	31553.09.01 Mt. Vernon School	MV-WF-014	7090606-14	Potable Water	08/28/2017 00:00:00	09/14/2017 16:18:12	EPA 200.5	Lead	7439-92-1	3.79	ug/L
2nd Floor / Room 241	31553.09.01 Mt. Vernon School	MV-WF-015	7090606-15	Potable Water	08/28/2017 00:00:00	09/14/2017 16:20:11	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Room 238	31553.09.01 Mt. Vernon School	MV-WF-016	7090606-16	Potable Water	08/28/2017 00:00:00	09/14/2017 16:22:10	EPA 200.5	Lead	7439-92-1	10.6	ug/L
2nd Floor / Hallway adj. to Room 237	31553.09.01 Mt. Vernon School	MV-WF-017	7090606-17	Potable Water	08/28/2017 00:00:00	09/14/2017 16:39:56	EPA 200.5	Lead	7439-92-1	1.98	ug/L
2nd Floor / Hallway adj. to Room 237	31553.09.01 Mt. Vernon School	MV-WF-018	7090606-18	Potable Water	08/28/2017 00:00:00	09/14/2017 16:41:55	EPA 200.5	Lead	7439-92-1	4.29	ug/L
2nd Floor / Room 228	31553.09.01 Mt. Vernon School	MV-WF-019	7090606-19	Potable Water	08/28/2017 00:00:00	09/14/2017 16:43:53	EPA 200.5	Lead	7439-92-1	17.6	ug/L
2nd Floor / Room 233	31553.09.01 Mt. Vernon School	MV-WF-020	7090606-20	Potable Water	08/28/2017 00:00:00	09/14/2017 16:45:51	EPA 200.5	Lead	7439-92-1	1.74	ug/L
2nd Floor / Room 226	31553.09.01 Mt. Vernon School	MV-WF-021	7090606-21	Potable Water	08/28/2017 00:00:00	09/14/2017 16:47:50	EPA 200.5	Lead	7439-92-1	1.39	ug/L
2nd Floor / Room 231	31553.09.01 Mt. Vernon School	MV-WF-022	7090606-22	Potable Water	08/28/2017 00:00:00	09/14/2017 16:49:49	EPA 200.5	Lead	7439-92-1	2.24	ug/L
2nd Floor / Room 215	31553.09.01 Mt. Vernon School	MV-WF-023	7090606-23	Potable Water	08/28/2017 00:00:00	09/14/2017 16:51:48	EPA 200.5	Lead	7439-92-1	ND	ug/L

IRVINGTON BOARD OF EDUCATION
Mt. Vernon School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPLE DATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
2nd Floor / Hallway adj. to Room 209	31553.09.01 Mt. Vernon School	MV-WF-024	7090606-24	Potable Water	08/28/2017 00:00:00	09/14/2017 16:59:44	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Room 202	31553.09.01 Mt. Vernon School	MV-WF-025	7090606-25	Potable Water	08/28/2017 00:00:00	09/14/2017 17:01:45	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Room 412	31553.09.01 Mt. Vernon School	MV-WF-026	7090606-26	Potable Water	08/28/2017 00:00:00	09/14/2017 17:03:45	EPA 200.5	Lead	7439-92-1	1.25	ug/L
1st Floor / Room 143	31553.09.01 Mt. Vernon School	MV-WF-027	7090606-27	Potable Water	08/28/2017 00:00:00	09/14/2017 17:15:46	EPA 200.5	Lead	7439-92-1	2.77	ug/L
1st Floor / Room 141	31553.09.01 Mt. Vernon School	MV-WF-028	7090606-28	Potable Water	08/28/2017 00:00:00	09/14/2017 17:17:46	EPA 200.5	Lead	7439-92-1	1.72	ug/L
1st Floor / Room 140	31553.09.01 Mt. Vernon School	MV-WF-029	7090606-29	Potable Water	08/28/2017 00:00:00	09/14/2017 17:25:43	EPA 200.5	Lead	7439-92-1	2.58	ug/L
1st Floor / Room 138	31553.09.01 Mt. Vernon School	MV-WF-030	7090606-30	Potable Water	08/28/2017 00:00:00	09/14/2017 17:27:43	EPA 200.5	Lead	7439-92-1	6.18	ug/L
1st Floor / Room 139	31553.09.01 Mt. Vernon School	MV-WF-031	7090606-31	Potable Water	08/28/2017 00:00:00	09/14/2017 17:29:44	EPA 200.5	Lead	7439-92-1	4.86	ug/L
1st Floor / Room 135	31553.09.01 Mt. Vernon School	MV-WF-032	7090606-32	Potable Water	08/28/2017 00:00:00	09/14/2017 17:31:45	EPA 200.5	Lead	7439-92-1	8.20	ug/L
1st Floor / Room 136	31553.09.01 Mt. Vernon School	MV-WF-033	7090606-33	Potable Water	08/28/2017 00:00:00	09/14/2017 17:33:45	EPA 200.5	Lead	7439-92-1	58.7	ug/L
1st Floor / Room 133	31553.09.01 Mt. Vernon School	MV-WF-034	7090606-34	Potable Water	08/28/2017 00:00:00	09/14/2017 17:35:46	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway	31553.09.01 Mt. Vernon School	MV-WF-035	7090606-35	Potable Water	08/28/2017 00:00:00	09/14/2017 17:37:45	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Hallway	31553.09.01 Mt. Vernon School	MV-WF-036	7090606-36	Potable Water	08/28/2017 00:00:00	09/14/2017 17:39:45	EPA 200.5	Lead	7439-92-1	6.23	ug/L
1st Floor / Room 128	31553.09.01 Mt. Vernon School	MV-WF-037	7090606-37	Potable Water	08/28/2017 00:00:00	09/14/2017 17:57:43	EPA 200.5	Lead	7439-92-1	25.4	ug/L
1st Floor / Room 126	31553.09.01 Mt. Vernon School	MV-WF-038	7090606-38	Potable Water	08/28/2017 00:00:00	09/14/2017 17:59:43	EPA 200.5	Lead	7439-92-1	2.97	ug/L
1st Floor / Room 131	31553.09.01 Mt. Vernon School	MV-WF-039	7090606-39	Potable Water	08/28/2017 00:00:00	09/14/2017 18:01:43	EPA 200.5	Lead	7439-92-1	0.883	ug/L
1st Floor / Central Corridor	31553.09.01 Mt. Vernon School	MV-WF-040	7090606-40	Potable Water	08/28/2017 00:00:00	09/14/2017 18:03:43	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Central Corridor	31553.09.01 Mt. Vernon School	MV-WF-041	7090606-41	Potable Water	08/28/2017 00:00:00	09/14/2017 18:05:43	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Corridor adj. To Stair 4	31553.09.01 Mt. Vernon School	MV-WF-042	7090606-42	Potable Water	08/28/2017 00:00:00	09/14/2017 18:07:44	EPA 200.5	Lead	7439-92-1	ND	ug/L
1st Floor / Corridor adj. To Stair 4	31553.09.01 Mt. Vernon School	MV-WF-044	7090606-44	Potable Water	08/28/2017 00:00:00	09/14/2017 18:09:43	EPA 200.5	Lead	7439-92-1	1.16	ug/L
Kitchen	31553.09.01 Mt. Vernon School	MV-KF-01 Kitchen	7090606-45	Potable Water	08/28/2017 00:00:00	09/14/2017 18:17:40	EPA 200.5	Lead	7439-92-1	41.2	ug/L

IRVINGTON BOARD OF EDUCATION
Mt. Vernon School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPLE DATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
Kitchen	31553-09-01 Mt. Vernon School	MV-KF-02 Kitchen	7090606-46	Potable Water	08/28/2017 00:00:00	09/14/2017 18:19:41	EPA 200.5	Lead	7439-92-1	114	ug/L
Kitchen	31553-09-01 Mt. Vernon School	MV-KF-03 Kitchen	7090606-47	Potable Water	08/28/2017 00:00:00	09/14/2017 18:21:42	EPA 200.5	Lead	7439-92-1	27.9	ug/L

IRVINGTON BOARD OF EDUCATION
Madison Avenue School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPLE DATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
2nd Floor / Hallway adj. to Room 20	31553.09.01 Madison Avenue School	MAD-WF-01	7090816-01	Potable Water	08/28/2017 00:00:00	09/14/2017 18:33:43	EPA 200.5	Lead	7439-92-1	ND	ug/L
2nd Floor / Hallway adj. to Room 25	31553.09.01 Madison Avenue School	MAD-WF-02	7090816-02	Potable Water	08/28/2017 00:00:00	09/14/2017 18:35:43	EPA 200.5	Lead	7439-92-1	55.7	ug/L
2nd Floor / Hallway adj. to Room 24	31553.09.01 Madison Avenue School	MAD-WF-03	7090816-03	Potable Water	08/28/2017 00:00:00	09/14/2017 18:43:39	EPA 200.5	Lead	7439-92-1	6.77	ug/L
1st Floor / Hallway adj. to Main Office	31553.09.01 Madison Avenue School	MAD-WF-04	7090816-04	Potable Water	08/28/2017 00:00:00	09/14/2017 18:45:40	EPA 200.5	Lead	7439-92-1	2.68	ug/L
1st Floor / Hallway adj. to Room 17	31553.09.01 Madison Avenue School	MAD-WF-05	7090816-05	Potable Water	08/28/2017 00:00:00	09/14/2017 18:47:40	EPA 200.5	Lead	7439-92-1	18.7	ug/L
1st Floor / Hallway adj. to Room 18	31553.09.01 Madison Avenue School	MAD-WF-06	7090816-06	Potable Water	08/28/2017 00:00:00	09/14/2017 18:49:40	EPA 200.5	Lead	7439-92-1	786	ug/L
Ground Floor / Hallway adj. to Room 3	31553.09.01 Madison Avenue School	MAD-WF-07	7090816-07	Potable Water	08/28/2017 00:00:00	09/14/2017 18:51:40	EPA 200.5	Lead	7439-92-1	ND	ug/L
Ground Floor / Hallway adj. to Room 4	31553.09.01 Madison Avenue School	MAD-WF-08	7090816-08	Potable Water	08/28/2017 00:00:00	09/14/2017 18:53:40	EPA 200.5	Lead	7439-92-1	92.2	ug/L

IRVINGTON BOARD OF EDUCATION
Thurgood Marshall School

PROJECT LOCATION	PROJECT NO.	SAMPLE NAME	LAB ID	MATRIX	SAMPLE DATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1st Floor / Hallway adj. to Room 107	Thurgood Marshall School	TMS-WF-01	7091109-01	Potable Water	08/29/2017 00:00:00	09/14/2017 18:55:40	EPA 200.5	Lead	7439-92-1	1.13	ug/L
1 st Floor / Hallway adj. to Room 107	Thurgood Marshall School	TMS-WF-02	7091109-02	Potable Water	08/29/2017 00:00:00	09/14/2017 18:57:40	EPA 200.5	Lead	7439-92-1	5.52	ug/L
1 st Floor / Hallway adj. to Room 105	Thurgood Marshall School	TMS-WF-03	7091109-03	Potable Water	08/29/2017 00:00:00	09/14/2017 19:15:41	EPA 200.5	Lead	7439-92-1	4.17	ug/L
1 st Floor / Hallway adj. to Room 105	Thurgood Marshall School	TMS-WF-04	7091109-04	Potable Water	08/29/2017 00:00:00	09/14/2017 19:17:41	EPA 200.5	Lead	7439-92-1	1.10	ug/L
1 st Floor / All Purpose Room (adj. to Stage)	Thurgood Marshall School	TMS-WF-08	7091109-08	Potable Water	08/29/2017 00:00:00	09/14/2017 19:19:41	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway adj. to Computer Room 216	Thurgood Marshall School	TMS-WF-011	7091109-11	Potable Water	08/29/2017 00:00:00	09/14/2017 19:21:41	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway adj. to Computer Room 216	Thurgood Marshall School	TMS-WF-012	7091109-12	Potable Water	08/29/2017 00:00:00	09/14/2017 19:23:41	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway adj. to Classroom 203	Thurgood Marshall School	TMS-WF-013	7091109-13	Potable Water	08/29/2017 00:00:00	09/14/2017 19:25:42	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway adj. to Classroom 205	Thurgood Marshall School	TMS-WF-014	7091109-14	Potable Water	08/29/2017 00:00:00	09/14/2017 19:27:41	EPA 200.5	Lead	7439-92-1	ND	ug/L

IRVINGTON BOARD OF EDUCATION
University Elementary School

PROJECT LOCATION	PROJECT NO	SAMPLE NAME	LAB ID	MATRIX	SAMPLE DATE	ANALYSIS DATE	METHOD NAME	ANALYTE	CAS NUMBER	RESULTS	UNITS
1 st Floor / Hallway outside Stair #1	University Elementary School	UES-WF-01	7091110-01	Potable Water	08/30/2017 00:00:00	09/14/2017 19:35:39	EPA 200.5	Lead	7439-92-1	1.16	ug/L
1 st Floor / Hallway outside General Office 173	University Elementary School	UES-WF-02	7091110-02	Potable Water	08/30/2017 00:00:00	09/14/2017 19:37:40	EPA 200.5	Lead	7439-92-1	ND	ug/L
1 st Floor / Hallway outside Conference Room 165	University Elementary School	UES-WF-03	7091110-03	Potable Water	08/30/2017 00:00:00	09/14/2017 19:39:40	EPA 200.5	Lead	7439-92-1	ND	ug/L
1 st Floor / Hallway adj. to Stair #5	University Elementary School	UES-WF-04	7091110-04	Potable Water	08/30/2017 00:00:00	09/14/2017 19:51:43	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway outside Stair #1	University Elementary School	UES-WF-05	7091110-05	Potable Water	08/30/2017 00:00:00	09/14/2017 19:53:44	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway adj. to Room 247	University Elementary School	UES-WF-06	7091110-06	Potable Water	08/30/2017 00:00:00	09/14/2017 20:01:41	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway adj. to Room 243	University Elementary School	UES-WF-07	7091110-07	Potable Water	08/30/2017 00:00:00	09/14/2017 20:03:41	EPA 200.5	Lead	7439-92-1	ND	ug/L
2 nd Floor / Hallway adj. to Room 243	University Elementary School	UES-WF-08	7091110-08	Potable Water	08/30/2017 00:00:00	09/14/2017 20:05:42	EPA 200.5	Lead	7439-92-1	ND	ug/L
3 rd Floor / Hallway outside Room 345	University Elementary School	UES-WF-010	7091110-10	Potable Water	08/30/2017 00:00:00	09/14/2017 20:07:43	EPA 200.5	Lead	7439-92-1	ND	ug/L
3 rd Floor / Special Ed Room 322	University Elementary School	UES-WF-013	7091110-13	Potable Water	08/30/2017 00:00:00	09/14/2017 20:09:43	EPA 200.5	Lead	7439-92-1	5.67	ug/L
3 rd Floor / Room 314	University Elementary School	UES-WF-015	7091110-15	Potable Water	08/30/2017 00:00:00	09/14/2017 20:11:43	EPA 200.5	Lead	7439-92-1	4.90	ug/L
3 rd Floor / Room 305	University Elementary School	UES-WF-016	7091110-16	Potable Water	08/30/2017 00:00:00	09/14/2017 20:13:44	EPA 200.5	Lead	7439-92-1	4.11	ug/L
3 rd Floor / Room 306	University Elementary School	UES-WF-017	7091110-17	Potable Water	08/30/2017 00:00:00	09/14/2017 20:15:44	EPA 200.5	Lead	7439-92-1	11.5	ug/L
3 rd Floor / Room 309	University Elementary School	UES-WF-018	7091110-18	Potable Water	08/30/2017 00:00:00	09/14/2017 20:43:47	EPA 200.5	Lead	7439-92-1	19.2	ug/L
3 rd Floor / Room 310	University Elementary School	UES-WF-019	7091110-19	Potable Water	08/30/2017 00:00:00	09/14/2017 20:45:48	EPA 200.5	Lead	7439-92-1	13.8	ug/L
Kitchen	University Elementary School	UES-KF-01Kitchen	7091110-20	Potable Water	08/30/2017 00:00:00	09/14/2017 20:53:47	EPA 200.5	Lead	7439-92-1	2.22	ug/L
Kitchen	University Elementary School	UES-KF-02Kitchen	7091110-21	Potable Water	08/30/2017 00:00:00	09/14/2017 20:55:48	EPA 200.5	Lead	7439-92-1	16.4	ug/L
Kitchen	University Elementary School	UES-KF-03 Kitchen	7091110-22	Potable Water	08/30/2017 00:00:00	09/14/2017 20:57:48	EPA 200.5	Lead	7439-92-1	3.70	ug/L